





SECTION B-B



SECTION A-A



DETAIL A
SCALE 1 : 1

SPECIAL REQUIREMENTS

BONDED WINDOWS

1. ROUTE COVER FACE DOWN AND REMOVE THE TWO MOUNTING BOSS' WHEN REQUIRED.

2. ROUGH BOTH SURFACES BEFORE BONDING.MINIMUM OVERLAP BETWEEN THE WINDOW AND THE ENCLOSURE IS 0.312".ACRYLIC NEEDS TO BE A MINIMUM 0.125" THICKNESS FOR OPENING SIZES UP TO 14-3/8" X 18-3/8" AND A MINIMUM 0.375" THICKNESS FOR OPENING SIZES LARGER THAN 14-3/8" X 18-3/8" UP TO 31-3/8" X 44-3/8".WINDOW MATERIAL THICKNESS MAY FLUCTUATE ACCORDING TO MANUFACTURE SPECIFIED TOLERANCES:

SAR/CLASS B: [0.125"+.020 & -.030] [0.375"+.030 & -.060].
ACRYLITE A/2: NOMINAL SIZE 0.354"+/-.018

UL FILE #E64358,VOL.1,SEC.GEN TYPE RATINGS 1,3R,4X,12.

NOTES: UL/CSA TYPE 1, 3R, 4X, 12

COLOR GLACIER GRAY RR3013 ; CLEAR ACRYLIC

MATERIAL: FR POLYESTER FIBERGLASS

DR. BY: DEVI — DATE: 11/11/2009

LTR	REVISION RECORD	DATE	BY	CHD
-	-	-	-	-
-	-	-	-	-
-	-	-	-	-
-	-	-	-	-
-	-	-	-	-

CHK. BY — DATE

APD. BY — DATE

SCALE: DO NOT SCALE

ALL DIMENSIONS ARE INCHES (MILLIMETERS) UNLESS SPECIFIED

TOLERANCES UNLESS SPECIFIED .XX ± 0.03(0.79) .XXX ± 0.010 (0.25)

HUBBELL WIEGMANN

CUSTOMER

CAD DWG.FILE: HW-N4X302410CHW

SHT 1 OF 1

PART NAME: ENCLOSURE

PART NO.: HW-N4X302410CHW